

§F307.5 Open-flame cooking devices. Charcoal burners and other open-flame cooking devices shall not be operated on combustible balconies or within 10 feet (3.1 m) of combustible construction.

EXCEPTIONS:

1. One-and two-family dwellings.
2. Where buildings, balconies and decks are protected by an approved automatic sprinkler system.